

Government of Andhra Pradesh
Rural water Supply and Sanitation Department
Internal Water Quality Monitoring Laboratory
RWS&S Division , TIRUPATHI
TEST REPORT ON BACTERIOLOGICAL ANALYSIS (DRINKING)


Name: Velammal Vidyalaya

S.No	Date of collection	Date of Report	Name of the Mandal	Grama Panchayat	Habitation	Location	Type of Source	Free Residual chlorine	H2s producing bacteria	Coliform / CFU/100	E.coli / CFU/100	Remark
1	2	3	4	5	6	7	8	9	10	11	12	13
1	25.09.2026	26.09.2026	Tirupati Urban	Thimminaidupalem	Thimminaidupalem	22 nd Ward, 1 st Block	DP	0.2	Negative	<1	0	Safe
2	25.09.2026	26.09.2026	Tirupati Urban	Thimminaidupalem	Thimminaidupalem	22 nd Ward, 1 st Block	RO	0	Negative	<1	0	Safe

Results : Coliform bacteria and E.coli bacteria is not detected in 100 ml water sample

Remarks : As per drinking water - specification (IS 10500:2012 , the total coliform bacteria and E.Coli or Thermo coliform bacterial shall not be detected in any 100 mlof water sample which is intended for drinking purpose.

Note : The above said result are related to the sample tested only.


26/09/26
Lab Microbiologist
RWS &S Division,
Chandragiri-1@Tirupati


26/09/26
Assistant Engineer
RWS &S Sub Division,
Tirupati(Addl)

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 003/AGE/T.P.T/2026

Dated: 26/09/26

It is certified that an inspection team headed by M. HEMADRI, AGE (Addl), T.P.T (R)
(Name of Officers with designation) from RWS&S Division, T.P.T Inspected the
**VELAMMAL VIDAYALA at 22nd Ward 4th BLOCK, THIRUMALA REDDY NAGAR, YADAVAS
VILLAGE, THIMINAIDUPALAM, TIRUPATI - 517501, ANDRA PRADESH** on 25/09/26
(date of inspection) and on the basis of Water Test Report (Attached) bearing no 02
dated 26/09/26 of WQM Lab (~~PHED~~ Lab) certified of that the **VELAMMAL
VIDAYALA** has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building &
the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 26/09/27


Asst Engineer 26/9/26
R.W.S. & S Sub-Division
Chandragiri-I

Signature with Seal: _____

Name: M. HEMADRI

Designation: AGE (Addl), T.P.T (R)

Name & Address of the Office / Department: RWS&S Division Office, Tirupati

To

VELAMMAL VIDAYALA
22nd Ward 4th BLOCK,
THIRUMALA REDDY NAGAR,
YADAVAS VILLAGE, THIMINAIDUPALAM,
TIRUPATI - 517501, ANDRA PRADESH