

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

C.No. 391

Date: 07.10.2026

It is certified that an inspection team headed by **R. RAMESH, SANITARY INSPECTOR** from **GREATER CHENNAICORPORTATION** verified the **VELAMMAL ACADEMY, VELAMMAL AVENUE, DOOR NO.27/1, GOVERTANAGIRI, PARUTHIPATTU, AVADI, CHENNAI-600071** on **01.10.2026**, and on the basis of Water Test Report (Attached) bearing **TR/2026/489-01** dated **06.10.2026** of **Chennai Metropolitan Water Supply and Sewerage Board, Water and Waste Water Testing Laboratory, Chennai 600010**, certified that the **VELAMMAL ACADEMY** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State / U.T. Govt.

The Certificate is valid for a period of **ONE YEAR** from the date of issue.

Signature with Seal:

R. Ramesh
07/10/26
R. RAMESH M.Sc.PG,DSI.

Name

Sanitary Inspector
Greater Chennai Corporation

Designation

SANITARY INSPECTOR

Name & Address of the Office / Department:

PUBLIC HEALTH DEPT

To,

**THE CORRESPONDENT,
VELAMMAL ACADEMY,
VELAMMAL AVENUE,
DOOR NO.27/1, GOVERTANAGIRI,
PARUTHIPATTU,
AVADI, CHENNAI-600071.**



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI – 600010.



NABLT0726TN18651

ULR No : NABLT0726TN186512600000423F		TEST REPORT - DRINKING WATER		Doc.No: CMWSSB/FRM/7.8/01	
Report No:	TR/2026/423-01	Report Issue Date:	30-09-2026	Page No	1 of 3
Challan No:	370	Challan Date:	25-09-2026	Amount (Rs)	2856/-

Client Name & Address & Contact No / Email.ID	Velammal Vidyalaya Velammal Avenue, Koladi Road, Paruthipattu Avadi Chennai - 71
--	---

Sample Name	: Water	Sample Description	: Drinking water
Sample Number	: 423	Sample Container	: Jerry Can
Sample Submitted by	: Customer	Location & Date	: RO Water, 25-09-2026
Sample Quantity	: 2 Litres	Sample Condition	: Good
Sample Received On	: 25-09-2026	Environmental Condition	: 23.0°C – 27.0°C
Test Commenced on	: 25-09-2026	Test Completed on	: 29-09-2026

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
1	Colour	CU	IS 3025: Part 4: 2021	2	5	15
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	0.6	1	5
4	pH @ 25°C	--	IS 3025: Part 11: 2022	6.92	6.5 To 8.5	6.5 To 8.5
5	Electrical Conductivity @25°C	µS/cm	IS 3025: Part 14: 2013	122	-	-
6	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	64	500	2000

---Contd---

Reviewed by
30/09/26
Water Analyst

M. Sudha
30/09/26
Authorised Signatory
M.Sudha Water Analyst

Note:

- The test results relate only to the items tested. & The result applied to the sample as received basis.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI – 600010.



NABLT0726TN18651

ULR No : NABLT0726TN186512600000423F

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:	TR/2026/423-01	Report Issue Date:	30-09-2026	Page No	2 of 3
Challan No:	370	Challan Date:	25-09-2026	Amount (Rs)	2856/-

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
7	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009	28	200	600
8	Calcium as Ca	mg/L	IS 3025: Part 40: 2024	8.0	75	200
9	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	BLQ(LOQ:5)	30	100
10	Chloride as Cl	mg/L	IS 3025: Part 32: 2025	20	250	1000
11	Total alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	30	200	600
12	Chlorine, Residual	mg/L	IS 3025: Part 26: 2021	BLQ(LOQ:0.2)	0.2	1.0
13	Ammonia as N	mg/L	IS 3025: Part 34: 1988	BLQ(LOQ:0.1)	0.5	No Relaxation
14	Nitrite as NO ₂	mg/L	IS 3025: Part 34: 1988	0.02	-	-
15	Fluoride as F	mg/L	IS 3025: Part 60: 2008	BLQ(LOQ:0.2)	1.0	1.5
16	Sulphate as SO ₄	mg/L	IS 3025: Part 24: Sec 1: 2022	5	200	400
17	Iron as Fe	mg/L	IS 3025: Part 53: 2024	0.10	0.3	No Relaxation

----Contd----

[Signature]
30/09/26
Reviewed by
Water Analyst

[Signature]
30/09/26
Authorised Signatory
M.Sudha Water Analyst

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI – 600010.

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:	TR/2026/423-02	Report Issue Date:	30-09-2026	Page No	3 of 3
Challan No:	370	Challan Date:	25-09-2026	Amount (Rs)	2856/-

Client Name & Address
& Contact No / Email.ID :
Velammal Vidyalaya
Velammal Avenue, Koladi Road, Paruthipattu
Avadi
Chennai - 71

Sample Name	: Water	Sample Description	: Drinking water
Sample Number	: 423	Sample Container	: Jerry Can
Sample Submitted by	: Customer	Location & Date	: RO Water, 25-09-2026
Sample Quantity	: 2 Litres	Sample Condition	: Good
Sample Received On	: 25-09-2026	Environmental Condition	: 23.0°C – 27.0°C
Test Commenced on	: 25-09-2026	Test Completed on	: 29-09-2026

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
1	Albuminoid Nitrogen	mg/L	CMWSSB SOP/001	0.03	-	-
2	Oxygen Absorbed @ 4 Hrs	mg/L	IS 3025: Part 63: 2007	0.27	-	-
3	Phosphate as P	mg/L	IS 3025: Part 31: Sec 1: 2022	0.015	-	-

BLQ: Below limit of Quantification LOQ: Limit of Quantification

Remarks:

The tested sample is conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters.

Reviewed by
30/09/26
Water Analyst

M. Sudha 30/09/26
Authorised Signatory
M.Sudha Water Analyst

Note:

- The test results relate only to the items tested. & The result applied to the sample as received basis.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.

-----End of Test Report-----